



**COCONUT INDUSTRY INVESTMENT FUND - Legaspi Oil Company, Inc.
Bids and Awards Committee I**

Bid Bulletin No. 1

July 29, 2024

Project Name: **Procurement of Supply of Labor, Materials, Supervision and other consumable for the Automation of Fire Suppression System of Legaspi Oil Company, Inc.**

Project Number: **LEG-2024-001 (PhilGEPS#11030219)**

This Supplemental/Bid Bulletin is issued to all prospective bidders to clarify, modify and/or amend pertinent items in the Philippine Bidding Documents as discussed and agreed during the Pre-Bid Conference held on July 23, 2024 for the abovementioned project of Coconut Industry Investment Fund – Legaspi Oil Company, Inc.

The following clarifications and amendment are provided for the guidance and reference of all prospective bidders:

CLARIFICATIONS

QUERY	CLARIFICATION/RESOLUTION
1. Is a bidder with a Category D license allowed to participate in the bidding given that the Approved Budget for the Contract is only 4,800,000.00?	1. No. The required Category is Category A – SP-FP Fire Protection Work.
2. What is the required pressure for jockey pump?	2. The required pressure for jockey pump is 226 psi.
3. What are the requirements for the fire pump? Should it include a complete set with the pump, motor, and controller?	3. LegOil requires only the fire pump controller, not the entire set. The pump and motor are already installed, as detailed on page 38 of the bidding documents under Section VII - Technical Specifications.
4. Is a site inspection required for the bidder?	4. The bidder is required to do the site inspection and shall submit the Site Inspection Certificate issued by the Procuring Entity’s representative during the eligibility checking.
5. Who will be responsible for the dismantling, the Bidder or the Procuring Entity?	5. The bidder shall do the dismantling.
6. After dismantling, will there be a need for pump rehabilitation?	6. There will be no rehabilitation of pumps.



**COCONUT INDUSTRY INVESTMENT FUND - Legaspi Oil Company, Inc.
Bids and Awards Committee I**

7. Are the three units of alarm check valves included?	7. Yes. The three units of alarm check valve are included.
--	--

All other portions of the Bidding Documents affected by these amendments shall be made to conform to the same.

Amendments/inclusions/clarifications made herein shall be made integral part of the Bidding Documents.

For information and guidance of all concerned.

Originally Signed

GERARDO GENARO F. ERESE

Vice-Chairperson, Bids and Awards Committee I